



Nov 13 2020  
LEAD & Copper

Department of Health and Human Services  
Health and Environmental Testing Laboratory

221 State Street  
#12 State House Station  
Augusta, ME 04333-0012  
Phone: (207)287-2727 Fax: (207)287-6832  
TTY: 1-800-606-0215  
EPA ID: ME00002

COUTURE, WILLIAM  
NEW ENGLAND MUSIC CAMP-KITCHEN  
8 GOLDENROD LANE  
SIDNEY ME 04330

Logged: 11/13/2020 2:21:57PM  
Folder #: 2010687  
Office Use Only:  
Line Item  
400899  
Public

Released: 11/17/2020

No. of Samples in Folder(s)	
2010687-01	TE4
2010687-02	TE4
2010687-03	TE4
2010687-04	TE4
2010687-05	TE4

**CERTIFICATION**

The HETL hereby certifies that all test results for this sample were analyzed by the method listed, including preservation, preparation, and holding times, unless otherwise indicated. For deficiencies not affecting the laboratory's ability to produce valid data, the HETL's accreditation status is now provisional for all environmental testing.

Kenneth G. Pole, PhD., Director                      Richard French, Quality Assurance Officer

If we can be of further assistance to you, please call us at 287-1716.

Approved by:

Christopher Montagna  
Inorganics Supervisor/Chemist III

**Lab Sample#:** 2010687-01

**Sample Matrix:** DW-H2O

**Description:** DISTRIBUTION SYSTEM / COFFEE POT SINK, DINING HALL

**Test Method/Analyte:** METALS\_200.8 (200.8)

Result	Unit	Qualifier	MCL	RL	High Limit	Low Limit	Analysis Date	Analyst
0.056	mg/L		1.3	0.0005			11/16/2020 14:50:00	C.S.
1.4	ug/L		15	0.5			11/16/2020 14:50:00	C.S.

**Lab Sample#:** 2010687-02

**Sample Matrix:** DW-H2O

**Description:** DISTRIBUTION SYSTEM / SALAD PREP SINK, KITCHEN

**Test Method/Analyte:** METALS\_200.8 (200.8)

Result	Unit	Qualifier	MCL	RL	High Limit	Low Limit	Analysis Date	Analyst
0.050	mg/L		1.3	0.0005			11/16/2020 14:55:00	C.S.
<0.5	ug/L		15	0.5			11/16/2020 14:55:00	C.S.

**Lab Sample#:** 2010687-03

**Sample Matrix:** DW-H2O

**Description:** DISTRIBUTION SYSTEM / BAKERS SINK, KITCHEN

**Test Method/Analyte:** METALS\_200.8 (200.8)

Result	Unit	Qualifier	MCL	RL	High Limit	Low Limit	Analysis Date	Analyst
0.020	mg/L		1.3	0.0005			11/16/2020 15:05:00	C.S.
<0.5	ug/L		15	0.5			11/16/2020 15:05:00	C.S.

**Lab Sample#:** 2010687-04

**Sample Matrix:** DW-H2O

**Description:** DISTRIBUTION SYSTEM / MENS BATHROOM, LEFT SINK

**Test Method/Analyte:** METALS\_200.8 (200.8)

Result	Unit	Qualifier	MCL	RL	High Limit	Low Limit	Analysis Date	Analyst
0.016	mg/L		1.3	0.0005			11/16/2020 15:10:00	C.S.
<0.5	ug/L		15	0.5			11/16/2020 15:10:00	C.S.

**Lab Sample#:** 2010687-05

**Sample Matrix:** DW-H2O

**Description:** DISTRIBUTION SYSTEM / WOMENS BATHROOM, LEFT SINK

**Test Method/Analyte:** METALS\_200.8 (200.8)

Result	Unit	Qualifier	MCL	RL	High Limit	Low Limit	Analysis Date	Analyst
0.045	mg/L		1.3	0.0005			11/16/2020 15:15:00	C.S.
<0.5	ug/L		15	0.5			11/16/2020 15:15:00	C.S.